



**STATE OF WASHINGTON
DEPARTMENT OF HEALTH**

OFFICE of ENVIRONMENTAL HEALTH and SAFETY

*243 Israel Road SE • PO Box 47824, Tumwater, WA 98504
(360) 236-3330 • 711 Washington Relay Service*

August 31, 2020

Cory Brandt
Slalom Construction
3038 198th Ave SE
Sammamish, WA 98075

Re: Proceed to Soil Inspection; Project 2020-019; Fall City Plat II On-site Sewage System (LOSS); System ID KIN061; King County

Dear Mr. Brandt:

The predesign report for the new proposed LOSS was received on July 31st, 2020.

We have determined that the conceptual design for the LOSS appears to be viable. **This letter is your notification to proceed to site inspection per WAC 246-272B-02000, with the following comments.**

- Your proposed LOSS is located above or near a Critical Aquifer Recharge Area (CARA). You may be required to provide additional treatment including nitrogen treatment. This requirement will be confirmed during the Environmental Review process.
- You must contact DAHP to confirm there are no concerns related to Tribal or Archaeological artifacts. At a minimum you will be required to implement an inadvertent discovery plan during all site work.

The fee for a site inspection, \$1000.00. Please submit your check, payable to the Department of Health with the enclosed invoice.

Mail to: DOH Accounts Receivable
PO Box 1099
Olympia, WA 98501-1099

If you fail to obtain all required approvals before construction, you will be subject to enforcement action, which may include civil penalties as authorized by chapter 70.118B RCW. Washington State Department of Health is under no obligation to accept or approve any component installed or constructed prior to approval. You may be required to expose system

Cory Brandt
September 1, 2020
Page 2

components for our inspection and rebuild/replace, if necessary, to meet LOSS rule requirements.

If you have any questions, please contact me at (360) 236-3378 or andrew.jones@doh.wa.gov.

Sincerely,

A handwritten signature in black ink, appearing to read "Andrew Jones". The signature is fluid and cursive, with a large initial "A" and "J".

Andrew Jones, P.E.,
Large On-site Sewage System Program
Wastewater Management Section

Enclosures

Invoice for Soil Inspection

cc: Andrew Jones, Department of Health
Frank Baird, Hydrogeologist, Department of Health
David Jensen, P.E., Jensen Engineering Inc.